

**Performance against minimum service standards  
(MSS) by Energex and Ergon Energy for the 2017-18  
financial year**

This publication has been compiled by <insert name/s> of <insert business group>, <insert department>.

© State of Queensland, 2019

The Queensland Government supports and encourages the dissemination and exchange of its information. The copyright in this publication is licensed under a Creative Commons Attribution 4.0 International (CC BY 4.0) licence.



Under this licence you are free, without having to seek our permission, to use this publication in accordance with the licence terms. You must keep intact the copyright notice and attribute the State of Queensland as the source of the publication.

Note: Some content in this publication may have different licence terms as indicated.

For more information on this licence, visit <https://creativecommons.org/licenses/by/4.0/>.

The information contained herein is subject to change without notice. The Queensland Government shall not be liable for technical or other errors or omissions contained herein. The reader/user accepts all risks and responsibility for losses, damages, costs and other consequences resulting directly or indirectly from using this information.

**Interpreter statement:**

The Queensland Government is committed to providing accessible services to Queenslanders from all culturally and linguistically diverse backgrounds. If you have difficulty in understanding this document, you can contact us within Australia on 13QGOV (13 74 68) and we will arrange an interpreter to effectively communicate the report to you.



## Table of contents

|  |          |
|--|----------|
| <b>Distributor performance</b> .....             | <b>1</b> |
| Background .....                                 | 1        |
| Minimum Service Standards .....                  | 1        |
| Distribution Networks .....                      | 1        |
| MSS requirements .....                           | 2        |
| Failure to perform within MSS limits .....       | 2        |
| <b>Summary of Energex performance</b> .....      | <b>3</b> |
| Performance against the MSS limits .....         | 3        |
| Performance against the SAIDI limits .....       | 3        |
| Performance against the SAIFI limits .....       | 3        |
| Excluded interruptions .....                     | 4        |
| Major event days .....                           | 5        |
| <b>Summary of Ergon Energy performance</b> ..... | <b>6</b> |
| Performance against the MSS limits .....         | 6        |
| Performance against the SAIDI limits .....       | 6        |
| Performance against the SAIFI limits .....       | 6        |
| Excluded interruptions .....                     | 7        |
| Major event days .....                           | 8        |

# Distributor performance

## Background

There are currently two Queensland distribution entities: Energex Limited (Energex) in South East Queensland and Ergon Energy Corporation Limited (Ergon Energy) in regional Queensland. Both entities operate distribution networks under Distribution Authorities issued to them by the Regulator under the *Electricity Act 1994* and administered by the Department of Natural Resources, Mines and Energy.

From 1 July 2014, as part of ongoing reforms to the Queensland electricity sector, the minimum service standards (MSS) of electricity distributors, and the requirement for them to report their performances against the MSS, were incorporated into their respective Distribution Authorities.

Prior to this date, the MSS and reporting requirements were contained within the Electricity Industry Code, and the reports were published online by the Queensland Competition Authority (QCA).

## Minimum Service Standards

The conditions of the Distribution Authorities held by Energex and Ergon Energy require that they use their best endeavours to meet MSS in relation to the frequency and duration of electricity distribution outages. The MSS are put in place to ensure that Queensland electricity customers receive a minimum prescribed level of supply reliability. If a distributor does not meet its MSS limits, it must provide reasons for any failure and a proposal to improve its performance.

The MSS limits for Energex and Ergon Energy differ, with those set for Energex being more stringent. This reflects the differences in their distribution networks, and the environments in which they operate.

Under the conditions of their Distribution Authorities, each entity is required to report on its performance against MSS limits within two months of the end of each quarter. Once the June quarterly report of each entity is received, DEWS can ascertain whether the distributor has performed within its MSS limits for the financial year.

This report details the performance of Energex and Ergon Energy against the MSS limits set for the 2017-18 financial year.

## Distribution Networks

The MSS reports are not intended to enable performance comparisons between Energex and Ergon Energy. Due to their very different operating environments and distribution network characteristics, any such comparison would be inappropriate. The MSS reports can, however, be used to gauge the year-on-year performance of each distributor.

The Energex distribution network supplies largely urbanised areas of South East Queensland. Ergon Energy's network is spread across the remainder of the state with a significant number of long, isolated feeders and lower customer densities. The individual prescribed MSS limits for each distribution entity reflect these network differences.

## MSS requirements

The MSS requirements are set in relation to the frequency and duration of interruptions to the distribution services provided by Energex and Ergon Energy. An interruption includes any temporary unavailability of electricity supply to a customer associated with an outage of the electricity distribution network.

The MSS are average measures of performance across each distribution network (categorised by feeder type) excluding the impact of certain excluded events such as severe weather events. To ensure a low probability of exceeding their MSS limits in a particular year, distributors must aim to achieve a higher level of performance than the MSS limits. The MSS limits for each financial year are detailed in the Distribution Authority of each distribution entity.

There are six MSS limits for each distributor. Three MSS limits relate to the average duration of service interruptions and three to the average frequency of service interruptions. Reliability performance is expressed using the following measures:

- a) **System average interruption duration index (SAIDI)** is the sum of all customer interruption durations (measured in minutes) divided by the total number of customers (averaged over the financial year) for each distributor; and
- b) **System average interruption frequency index (SAIFI)** is the total number of customer interruptions, divided by the total number of customers (averaged over the financial year) for each distributor.

SAIDI and SAIFI performance is measured and reported based on the broad feeder categories of central business district (CBD), urban, short rural and long rural feeders. The MSS limits differ between feeder types, reflecting the performance that should reasonably be achieved on each type.

Some interruptions may be excluded by the distributors when reporting performance against MSS limits. Possible exclusions include interruptions commencing on a major event day, interruptions of one minute or less (momentary interruptions), interruptions resulting from a failure of the shared transmission grid, and interruptions caused by the failure of a customer's electrical installation. Interruptions resulting from a direction by a police officer or other authorised person who is exercising powers in relation to public safety are also excluded. A complete list of excluded interruptions is set out in the Distribution Authority of each distribution entity.

## Major event days

A major event day is one where the daily SAIDI value exceeds a certain threshold, which is based on the distributor's historical reliability performance. Major event days are often associated with severe weather events that cause significant, widespread and prolonged customer supply interruptions. Major event days are excluded when assessing the performance of distributors against MSS limits.

## Failure to perform within MSS limits

If a distributor exceeds the same MSS limit (i.e. SAIDI limit or SAIFI limit) for three financial years in a row, this is considered a 'systemic failure' and represents a contravention of the conditions of the entity's distribution authority. Under the *Electricity Act 1994*, any such contravention may incur disciplinary action such as the cancellation or suspension of a distribution authority and/or the imposition of a pecuniary civil penalty.

## Summary of Energex performance

### Performance against the MSS limits

Energex's reliability performance for 2017-18 was favourable to the MSS for all six performance measures.

Energex's SAIDI and SAIFI performance before and after exclusions, and its MSS limits for 2017-18 (as prescribed in its distribution authority) are presented in Tables 1 and 2.

Table 3 details the interruptions that Energex has excluded in determining performance against its SAIDI and SAIFI limits during 2017-18.

Energex reported six major event days during 2017-18, these are detailed in Table 4.

### Performance against the SAIDI limits

**Table 1 Energex SAIDI performance (minutes)**

|                                | 2013-14* | 2014-15 | 2015-16 | 2016-17 | 2017-18        | SAIDI MSS limits 2017-18 |
|--------------------------------|----------|---------|---------|---------|----------------|--------------------------|
| <b>Total before exclusions</b> |          |         |         |         |                |                          |
| CBD feeders                    | 4.069    | 3.699   | 28.278  | 7.953   | 4.803          |                          |
| Urban feeders                  | 94.944   | 190.512 | 85.916  | 131.562 | 130.872        |                          |
| Short rural feeders            | 232.873  | 263.357 | 258.085 | 520.825 | 381.706        |                          |
| <b>Total net of exclusions</b> |          |         |         |         |                |                          |
| CBD feeders                    | 3.560    | 3.699   | 4.680   | 3.840   | <b>4.799</b>   | <b>15</b>                |
| Urban feeders                  | 74.864   | 90.813  | 76.670  | 76.261  | <b>73.092</b>  | <b>106</b>               |
| Short rural feeders            | 173.392  | 178.592 | 180.890 | 164.641 | <b>187.384</b> | <b>218</b>               |

\* previously reported by the QCA

### Performance against the SAIFI limits

**Table 2 Energex SAIFI performance (number of interruptions)**

|                                | 2013-14* | 2014-15 | 2015-16 | 2016-17 | 2017-18       | SAIFI MSS limits 2017-18 |
|--------------------------------|----------|---------|---------|---------|---------------|--------------------------|
| <b>Total before exclusions</b> |          |         |         |         |               |                          |
| CBD feeders                    |          | 0.158   | 0.131   | 0.044   | 0.0355        |                          |
| Urban feeders                  | 0.184    | 0.957   | 0.793   | 0.842   | 0.8649        |                          |
| Short rural feeders            | 0.916    | 1.861   | 1.760   | 1.991   | 1.8566        |                          |
| <b>Total net of exclusions</b> |          |         |         |         |               |                          |
| CBD feeders                    | 0.058    | 0.158   | 0.032   | 0.024   | <b>0.0352</b> | <b>0.150</b>             |
| Urban feeders                  | 0.804    | 0.786   | 0.740   | 0.671   | <b>0.6712</b> | <b>1.260</b>             |
| Short rural feeders            | 1.556    | 1.546   | 1.562   | 1.453   | <b>1.4561</b> | <b>2.460</b>             |

\* previously reported by the QCA

## Excluded interruptions

**Table 3 Energex exclusions from MSS reporting for 2017-18**

|   | Exclusions from SAIDI (minutes) | Exclusions from SAIFI (interruptions) |
|---|---------------------------------|---------------------------------------|
| <b>Interruption of a duration of one minute or less</b>   |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from load shedding due to a shortfall in generation</b>   |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from a direction by AEMO, a system operator or any other body exercising a similar function under the Electricity Act, National Electricity Rules or National Electricity Law</b>                                     |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from automatic shedding of load under the control of under-frequency relays following the occurrence of a power system under-frequency condition described in the power system security and reliability standards</b> |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from failure of the shared transmission grid</b>  |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| CBD feeder  | 0.000                           | 0.000                                 |
| Urban feeder  | 1.543                           | 0.0601                                |
| Short rural feeder  | 0.928                           | 0.0291                                |
| <b>Interruption from direction by police officer or other authorised person in relation to public safety</b>  |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| CBD feeder  | 0.000                           | 0.000                                 |
| Urban feeder  | 0.000                           | 0.000                                 |
| Short rural feeder  | 0.000                           | 0.000                                 |
| <b>Interruption to the supply of electricity on a distribution entity's supply network which commences on a major event day</b>   |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| CBD feeder  | 0.000                           | 0.0003                                |
| Urban feeder  | 56.199                          | 0.1329                                |
| Short rural feeder  | 193.328                         | 0.3709                                |
| <b>Interruption caused by customer electrical installations</b>   |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| CBD feeder  | 0.000                           | 0.000                                 |
| Urban feeder  | 0.038                           | 0.0007                                |
| Short rural feeder  | 0.066                           | 0.0005                                |

| <b>Total exclusions</b> |                |               |
|-------------------------|----------------|---------------|
|                         | <b>SAIDI</b>   | <b>SAIFI</b>  |
| CBD feeder              | <b>0.004</b>   | <b>0.0003</b> |
| Urban feeder            | <b>57.780</b>  | <b>0.1937</b> |
| Short rural feeder      | <b>194.322</b> | <b>0.4005</b> |

## Major event days

**Table 4 – Major event details**

| <b>Event Date/s</b>     | <b>Event Description</b>   |
|-------------------------|--|
| 9 December 2017         | Severe storms and lightning strikes impacted Sunshine Coast and surrounding areas                    |
| 25 December 2017        | Severe storms and lightning strikes impacted Brisbane South, Gold Coast and surrounding areas        |
| 31 December 2017        | Storm impacted the Energex network   |
| 11 and 12 February 2018 | Severe storms impacted Brisbane Metro South, Brisbane South-West and areas in the South Coast region |
| 16 February 2018        | Severe storms impacted Brisbane Metro South, South East areas and Central Districts                  |



## Summary of Ergon Energy performance

### Performance against the MSS limits

Ergon Energy's reliability performance for the 2017-18 regulatory year was favourable to the MSS for 6 of the 6 performance measures.

Ergon Energy's SAIDI and SAIFI performance before and after exclusions and its MSS limits for 2017-18 as prescribed in its distribution authority are presented in Tables 5 and 6.

Table 7 details the interruptions that Ergon Energy has excluded in determining performance against its SAIDI and SAIFI limits during 2017-18.

Ergon Energy reported nine major events during 2017-18, these are detailed in Table 8.

### Performance against the SAIDI limits

**Table 4 Ergon Energy SAIDI performance (minutes)**

|                                | 2013-14* | 2014-15   | 2015-16   | 2016-17  | 2017-18         | SAIDI MSS limits 2017-18 |
|--------------------------------|----------|-----------|-----------|----------|-----------------|--------------------------|
| <b>Total before exclusions</b> |          |           |           |          |                 |                          |
| Urban feeders                  | 165.62   | 836.4232  | 145.3321  | 482.095  | 211.5665        |                          |
| Short rural feeders            | 440.11   | 1042.8636 | 397.0792  | 1225.878 | 484.9407        |                          |
| Long rural feeders             | 850.86   | 1590.7802 | 1040.4344 | 1235.369 | 1259.9457       |                          |
| <b>Total net of exclusions</b> |          |           |           |          |                 |                          |
| Urban feeders                  | 118.49   | 133.6567  | 127.7016  | 106.988  | <b>134.0039</b> | <b>149</b>               |
| Short rural feeders            | 291.91   | 359.0826  | 349.5913  | 279.380  | <b>315.5424</b> | <b>424</b>               |
| Long rural feeders             | 798.42   | 1052.7546 | 954.7147  | 780.761  | <b>891.2906</b> | <b>964</b>               |

\* previously reported by the QCA

### Performance against the SAIFI limits

**Table 5 Ergon Energy SAIFI performance (number of interruptions)**

|                                | 2013-14* | 2014-15 | 2015-16 | 2016-17 | 2017-18       | SAIFI MSS limits 2017-18 |
|--------------------------------|----------|---------|---------|---------|---------------|--------------------------|
| <b>Total before exclusions</b> |          |         |         |         |               |                          |
| Urban feeders                  | 1.714    | 1.8846  | 1.3957  | 1.378   | 2.0537        |                          |
| Short rural feeders            | 3.169    | 3.8963  | 3.1983  | 3.098   | 3.5103        |                          |
| Long rural feeders             | 6.476    | 7.3054  | 7.1775  | 6.457   | 6.8572        |                          |
| <b>Total net of exclusions</b> |          |         |         |         |               |                          |
| Urban feeders                  | 1.394    | 1.2686  | 1.2723  | 1.135   | <b>1.519</b>  | <b>1.98</b>              |
| Short rural feeders            | 2.767    | 3.1501  | 3.0234  | 2.637   | <b>2.708</b>  | <b>3.95</b>              |
| Long rural feeders             | 6.118    | 6.7643  | 6.7663  | 5.804   | <b>5.5507</b> | <b>7.40</b>              |

\* previously reported by the QCA

## Excluded interruptions

Table 6 Ergon Energy exclusions from MSS reporting for 2017-18

|   | Exclusions from SAIDI (minutes) | Exclusions from SAIFI (interruptions) |
|---|---------------------------------|---------------------------------------|
| <b>Interruption of a duration of one minute or less</b>   |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from load shedding due to a shortfall in generation</b>   |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from a direction by AEMO, a system operator or any other body exercising a similar function under the Electricity Act, National Electricity Rules or National Electricity Law</b>                                     |                                 |                                       |
| None in 2017-18   |                                 |                                       |
| <b>Interruption resulting from automatic shedding of load under the control of under-frequency relays following the occurrence of a power system under-frequency condition described in the power system security and reliability standards</b> |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| Urban feeder  | 1.053                           | 0.0564                                |
| Short rural feeder  | 0.3713                          | 0.0201                                |
| Long rural feeder   | 1.1528                          | 0.0549                                |
| <b>Interruption resulting from failure of the shared transmission grid</b>  |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| Urban feeder  | 8.8299                          | 0.2409                                |
| Short rural feeder  | 6.1271                          | 0.1554                                |
| Long rural feeder   | 4.0225                          | 0.0745                                |
| <b>Interruption from direction by police officer or other authorised person in relation to public safety</b>  |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| Urban feeder  | 0.6785                          | 0.0142                                |
| Short rural feeder  | 3.4761                          | 0.0436                                |
| Long rural feeder   | 0.0872                          | 0.0006                                |
| <b>Interruption to the supply of electricity on a distribution entity's supply network which commences on a major event day</b>   |                                 |                                       |
|   | <b>SAIDI</b>                    | <b>SAIFI</b>                          |
| Urban feeder  | 66.9674                         | 0.2230                                |
| Short rural feeder  | 159.324                         | 0.5830                                |
| Long rural feeder   | 363.3092                        | 1.1761                                |

| <b>Interruption caused by customer electrical installations</b> |                 |               |
|---|-----------------|---------------|
|   | <b>SAIDI</b>    | <b>SAIFI</b>  |
| Urban feeder  | 0.0338          | 0.0003        |
| Short rural feeder  | 0.0999          | 0.0003        |
| Long rural feeder   | 0.0833          | 0.0004        |
| <b>Total exclusions</b>   |                 |               |
|   | <b>SAIDI</b>    | <b>SAIFI</b>  |
| Urban feeder  | <b>77.5626</b>  | <b>0.5347</b> |
| Short rural feeder  | <b>169.3983</b> | <b>0.8023</b> |
| Long rural feeder   | <b>368.6551</b> | <b>1.3065</b> |

## Major event days

**Table 8 – Major event details**

| <b>Event Date</b> | <b>Event Details</b>   |
|-------------------|--|
| 19 October 2017   | Severe storms, lightning strikes and heavy rainfall affecting Cairns, Rollingstone and adjacent inland areas |
| 7 November 2017   | Severe storms, lightning strikes and heavy rainfall affecting the Bundaberg region                           |
| 26 December 2017  | Severe storms impacting South Burnett, Toowoomba, Darling Downs and surrounding areas                        |
| 31 December 2017  | Severe storms impacting Bundaberg and surrounding areas  |
| 1 January 2018    | Severe storms impacting Rockhampton and surrounding areas  |
| 2 January 2018    | Severe storms impacting Dawson, Callide, Rockhampton, Port Curtis and surrounding areas                      |
| 16 February 2018  | Severe storms impacting the Fraser Burnett and Capricornia regions   |
| 20 February 2018  | Severe storms impacting Moranbah, Townsville and surrounding areas   |
| 17 April 2018     | Fault at South Bundaberg substation  |