MP 2.2 - FIRE SAFETY IN RESIDENTIAL CARE BUILDINGS

Index

Purpose	2
Commencement	2
Application	2
Referral agency	2
Associated requirements	2
Referenced standards	2
Definitions	2
Fire suppression system	5
Evacuation support	5
Early warning system	6
Schedule 1 - Evacuation impairment assessment checklist	7
Schedule 2 – Required elements of a residential care building fire and evacuation	plan8

Purpose

To ensure *residential care buildings* provide for the safe evacuation of occupants in the event of fire.

Commencement

This version of MP 2.2 commences on 4 April 2008 and replaces MP 2.2 published on 1 January 2008.

Application

This standard applies:

- (a) to residential care buildings where the building development application for construction is made on or after 4 April 2008; and
- (b) in addition to the requirements of the Building Code of Australia (*BCA*) for the relevant classification of the *building*.

Referral agency

The Queensland Fire and Rescue Service is an advice agency under Schedule 2 of the Integrated Planning Regulation 1998 for:

- (a) special fire services;
- (b) alternative solutions for fire safety systems assessed against the performance criteria of this standard and the performance criteria of Volume 1 of the BCA; and
- (c) fire and evacuation plans assessed against schedule 2 of this standard.

Associated requirements

- Building Act 1975
- Building Regulation 2006
- Integrated Planning Regulation 1998
- Local Government Act 1993
- Fire and Rescue Service Act 1990
- Building Fire Safety Regulation 1991
- Building Code of Australia (BCA)

Referenced standards

AS 1670.1	Fire detection, warning, control and intercom systems—Systems
	design, installation and commissioning – Part 1: Fire
AS 2118.1	Automatic fire sprinkler systems – Part 1: General requirements
AS 3786	Smoke alarms
AS 2118.4	Automatic fire sprinkler systems – Part 4: Residential

Definitions

Note: Italicised words within the body of the text are defined.

Acceptable solutions means solutions which are deemed to satisfy the performance criteria.

Aged care building has the meaning given in the BCA.

MP 2.2 - FIRE SAFETY IN RESIDENTIAL CARE BUILDINGS

Automatic has the meaning given in the BCA.

BCA means the edition of the Building Code of Australia in force at the time the relevant development application is lodged.

Building includes part of a building if the part is a separate fire compartment.

Class 1b has the meaning described in Part A3 of Volume One of the BCA.

Class 3 has the meaning described in Part A3 of Volume One of the BCA.

Class 9a has the meaning described in Part A3 of Volume One of the BCA.

Class 9c has the meaning described in Part A3 of Volume One of the BCA.

Evacuation impairment means an impairment or a combination of impairments which reduces the capacity of a person to evacuate in an emergency to the extent that the person requires *physical assistance* to safely evacuate the *building* in an emergency and includes any impairment that restricts mobility or the ability to understand or independently respond to an emergency evacuation as indicated by an assessment using the form in Schedule 1 of this standard.

Fire and evacuation plan means the *fire and evacuation plan* required for the *building* by s104E of the *Fire and Rescue Service Act 1990* with the elements listed in Schedule 2 of this standard.

Fire compartment has the meaning given in the BCA.

Fire hose reels means fire hose reels prescribed for the building in accordance with the BCA.

Floor area has the meaning given in the BCA.

Hospital means a building:

- (a) used to provide medical or surgical treatment to sick or injured persons; and
- (b) not used as a place of residence for persons who need *physical assistance* in conducting daily activities.

Minimum support ratio means the ratio obtained by comparing the lowest number of *on-site* responsible persons in the *building* at any time to the number of persons accommodated with an evacuation impairment in a smoke compartment.

On-site means, for the purposes of providing residents with *physical assistance* to evacuate the *building*:

- (a) located no more than 60 metres distance of travel from an entrance of the part of the *building* used to provide residential care; or
- (b) located and immediately available in the part of the building used to provide residential care.

Performance criteria means the outcome that must be achieved for an element of a building.

Physical assistance means with respect to assisting a person to evacuate the *building* in an emergency includes leading or monitoring a person, other than a child without an *evacuation impairment*, who would otherwise be unable to reliably and safely evacuate the *building*.

Public corridor has the meaning given in the BCA.

Residential aged care building has the meaning given in the BCA.

MP 2.2 - FIRE SAFETY IN RESIDENTIAL CARE BUILDINGS

Residential care building means a *building* which is a place of residence where 10% or more of persons who reside there need *physical assistance* in conducting their daily activities and to evacuate the *building* during an emergency (including any *aged care building*) but does not include:

- (a) a hospital; or
- (b) a dwelling in which 2 or more members of the same family and not more than 2 other persons would ordinarily be resident; or
- (c) a building accommodating five or less residents; or
- (d) a *building* in which only one resident requires *physical assistance* to conduct their daily activities and to evacuate the *building* during an emergency.

Responsible person means a person without an evacuation impairment nominated by the owner, manager or service provider of a residential care building to provide evacuation support to the building's occupants and who is:

- (a) on-site, alert and able to hear or otherwise immediately respond to an activation of the building's fire alarm at all times; or
- (b) if asleep and on duty in the part of the *building* used to provide residential care, able to hear and immediately respond to an activation of the *building*'s fire alarm at all times.

Safe place has the meaning given in the BCA.

Smoke alarm means device containing a smoke detector and an alarm sounder complying with AS 3786.

Smoke alarm system means a combination of *smoke alarms*.

Smoke detection system means a *smoke detection system* complying with AS 1670.1 as required by the *BCA*.

Smoke compartment means an area bounded by smoke proof walls complying with specification C2.5 of the *BCA* as it relates to *aged care buildings*.

Sprinkler system means a fire suppression system complying with AS 2118.1 or AS 2118.4 with fast response sprinkler heads designed for life safety applications.

Storey has the meaning given in the BCA.

Support means, for the purposes of *minimum support ratio*, immediate and effective *on-site* evacuation assistance, provided by a *responsible person* to a person with an *evacuation impairment*.

PERFORMANCE CRITERIA

ACCEPTABLE SOLUTIONS

Fire suppression system

- P1 In all residential care buildings an automatic fire suppression system, monitored by an approved system, must be installed to control the development and spread of fire appropriate to -
 - (a) the size and height of the building; and
 - (b) the fire hazard; and
 - (c) the number, mobility and other characteristics of the occupants.

A1 In all residential care buildings -

- (a) an *automatic sprinkler system* is installed in accordance with
 - (i) AS 2118.1; or
 - (ii) AS 2118.4 in buildings of not more than four storeys and of not more than 5000m² floor area; and
- (b) the *automatic sprinkler system* is provided with a monitored main stop valve in accordance with AS 2118.1 which is permanently connected with a direct data link to a fire station or fire dispatch centre except for buildings –
- (i) with a floor area of 300 m² or less; and
- (ii) with less than 13 residents; and
- (iii) that are not aged care buildings; and
- (c) BCA concessions for fire resistance as applicable to Class 9c aged care buildings are available for Class 9a buildings and fire resistance concessions applicable to Class 3 residential aged care buildings are available for Class 3 buildings; and
- (d) fire hose reels are not required to be installed.

Evacuation support

- P2 In all residential care buildings a level of immediate on-site evacuation assistance must be maintained to ensure occupants of the building can be safely evacuated in the event of an emergency appropriate to the mobility and other characteristics of the building's occupants.
 - **Note:** For the purposes of A2 a responsible person may provide evacuation support in more than one smoke compartment.

- **A2** (a) In all residential care buildings, a fire and evacuation plan is provided which-
 - (i) indicates a *minimum support ratio* is to be maintained at all times so that no more than ten occupants with an *evacuation impairment* are accommodated within any *smoke compartment* for each *on-site responsible person*; and
 - (ii) describes the arrangements to be used to ensure the *building's minimum support ratio* is maintained at all times; and
 - (iii) is conspicuously displayed in the building.

PERFORMANCE CRITERIA

ACCEPTABLE SOLUTIONS

Early warning system

- P3 In all residential care buildings not required to have a smoke detection system installed, occupants must be provided with appropriate automatic warning on the detection of smoke so they may evacuate in the event of fire to a safe place appropriate to
 - (a) the number, mobility and other characteristics of the occupants; and
 - (b) the need for a *responsible person* to provide other occupants of the *building* with evacuation *support*.
- A3 In all residential care buildings not required by the BCA to have a smoke detection system installed, smoke alarms are installed in every room, public corridor and other internal public spaces and located in accordance with the requirements for smoke detectors in AS 1670.1 and interconnected to provide common alarm.

Schedule 1 – Evacuation impairment assessment checklist

Residential care buildings EVACUATION IMPAIRMENT ASSESSMENT FORM

This form may be used to assess whether an occupant of the *building* has an *evacuation* impairment.

Use this form for the purposes of compliance with A2 of this code.

- (a) An occupant does not have an *evacuation impairment* when ALL answers on this form are ticked to indicate Yes. Do not indicate "Yes" in answer to any question unless the occupant is able to meet the criterion <u>at all times of the day or night</u>.
- (b) If this form is being used to exclude occupants from the need for evacuation *support*, the excluded person must be assessed upon admission and reassessed when the person's ability to evacuate in an emergency changes or otherwise monthly. Monthly evacuation drills should be used to determine the ability of a person to safely evacuate the *building* in the event of fire.
- (c) If the occupant has an evacuation impairment, you MUST include him/her in your minimum support ratio calculations. If the occupant does not have an evacuation impairment, you do not need to include him/her in your minimum support ratio calculations.
- (d) If this form is used to exclude an occupant from the requirement that they be provided with evacuation *support*, a copy must be available in the *building* for inspection by authorised persons under the *Local Government Act* 1993 or authorised fire officers of the Queensland Fire and Rescue Service at any time the *building* is occupied.

	Date of Drill:	
Name of Occupant:	Room Number:	
Name of <i>Building</i> :		
Name of Organisation:		
Assessed by:	(name)	(signature)

Does	s the occupant	Yes	No	Comments
	Demonstrate the ability to hear and ecognise the fire evacuation alarms?			
e e	Demonstrate the ability to safely evacuate from the <i>building</i> without the assistance of another person?			
e a	Demonstrate the ability to follow the evacuation plan and evacuate to the assembly point identified in the evacuation plan?			
e e	Demonstrate observance of the evacuation plan in a calm and timely nanner in a drill situation?			
, h	Demonstrate an understanding that be/she must comply with the directions of emergency personnel?			
Result				
	s the occupant have an evacuation irment?			

Schedule 2 – Required elements of a residential care building fire and evacuation plan

- 1. Building identification.
- 2. Allowable occupant numbers.
- 3. The proposed maintenance schedule for the *building*'s prescribed fire safety installations.
- 4. A plan of action to be taken in the event of fire or activation of the *building*'s fire alarm including:
- (a) written instructions with the following priorities:
 - (i) Investigate and raise the alarm as soon as a fire is suspected
 - (ii) Begin a thorough evacuation, beginning from the point of greatest risk
 - (iii) Summon the fire service
 - (iv) Contain or control the fire if safe to do so, and as long as the evacuation is not affected, and only if the evacuation has adequate supervision
 - (v) Assemble and account for persons
 - (vi) Occupants to be directed not to re-enter the building; and
- (b) a simple and legible diagram of the *building*, drawn to a reasonable scale, indicating the *building*'s evacuation routes, required exits and assembly points; and
- (c) arrangements for monitoring and training to ensure the *minimum support ratio* required by performance criterion two of this standard is maintained at all times; and
- (d) a list of persons (described by reference to the positions they hold or in another suitable way) responsible for administering the *building's fire and evacuation plan*.
- 5. The proposed instruction schedule to ensure the *building*'s workers and residents are adequately instructed concerning the actions to be taken by them in the event of fire threatening the *building* to ensure their own and other persons' safety.